

### **GRANITE Emergency Bulkhead**

Part numbers
BHA3-MT
BHA3-AST
BHA3-PST



**Specification:** Weatherproof (IP65) and robust (IK10) self-contained emergency LED bulkhead. Constant emergency light (3W/350lm) for 3 hours. Low stand-by power consumption. Self-test versions and remote controls available. Self-adhesive legend available for 20m viewing distance exit sign. Lithium battery as standard. Maintained, Switch Maintained or non-maintained configurations. Suitable for indoor and outdoor applications such as car parks, distribution centres, storage rooms and sports centres.



<sup>\*</sup> Self-test only available on AST and PST versions

#### **Key Features**

- Maintained and Non-maintained configurations
- Low stand-by power consumption (0.5 W)\*
- Fast battery re-charge (8 hrs)\*\*
- IP65 cable gland included
- Remote control available
- \* Non-maintained mode only
- \*\* First battery charge takes up to 16 hours

#### **GRANITE Emergency Bulkhead**

Part number	Description	Testing facility	Remote control part number *	Operating temperature	Net weight
BHA3-MT	EM LED bulkhead 3W 350lm MT	Manual Test (MT)	-		
BHA3-AST	EM LED bulkhead 3W 350lm AST	Advance Self-Test (AST)	ARC	0°C ~ 40°C	0.485kg
BHA3-PST	EM LED bulkhead 3W 350lm PST	Programmable Self-Test (PST)	PRC		

<sup>\*</sup> Advance Remote Control (ARC) allows the competent installer to carry out functional tests and/or full duration tests at any time and to check system's status. Please refer to ARC's user guide. In addition to ARC functions the Programmable Remote Control (PRC) allows the competent installer to programme the testing schedule of each emergency luminaire. Please refer to PRC's user guide.



## **GRANITE Emergency Bulkhead**

Technical information				
Input voltage/frequency	220-240V AC 50Hz			
Power consumption				
Maintained	4.5W(Max)			
Non-maintained	0.5W(standby)			
Lumen output				
On mains voltage	350lm			
On emergency mode	350lm			
LEDs Lifetime (L-70)	50,000h			
Discharge duration	3 hours			
Wh (maintained standby)	4.5			
Wh (non-maintained standby)	0.5			
Charge duration	up to 8hrs (first charge up to 16hrs)			
Test facility	MT, AST, PST			
IP rating	IP65			
IK rating	IK10			
Insulation class	II			
Operation temp.	0~40°C			
Storage temp.	0~50°C			

Materials						
Luminaire housing	Polycarbonate					
Luminaire diffuser	Polycarbonate					
Luminaire bracket	Polycarbonate					
Luminaire legend	N.A.					
Luminaire screws	SS 316					
Finish	Back Matt, Front smooth					
Colour	White					
Battery type	Li-lon 3.6V 5000mAh					

Logistic information							
Product dimensions (L x W x D)mm	355 x 109 x 60.8 mm						
Product Net weight (kg)	0.485kg						
Box dimensions (L x W x D)mm	360 x 112 x 70 mm						
Gross weight (kg)	0.596kg						
Quantity of outer carton	16 pc's						
Outer carton dimensions(L x W x D)mm	370 x 355 x 355 mm						
Outer carton gross weight (kg)	11.5kg						
Quantity per Euro pallet (1200 x 800)	360 pcs						
Pallet weight (kg)	10kg						

Light Source					
Brand	Everlight				
Quantity	12 pcs				
ССТ	4000K				
CRI	>80				

Certification	
Safety standard	BS EN 60598-2-22
Certified by	DEKRA
UKCA / CE / ENEC Mark	Yes
Factory QMS	ISO9001

### **INSTALLATION NOTES**

- Surface ceiling or wall mount
- BESA entry drilling template on rear
- IP65 and IK10 rating

- Cable entry to sides, top/bottom and rear (20mm cut-outs)
- Screwless terminal block (SL, L, N)
- Terminal block takes wires up to 3 x 2.5mm²
- Recess kit available (BHA-RK)

### **TESTING FACILITIES**

MT (Manual Test)	This luminaire needs to be tested by a competent person according to BS EN 50172:2004. This luminaire can be used in conjunction with the Advanced Remote Control (ARC). ARC is an optional tool that adds new features to AST and MT emergency luminaires. If functional test or full duration test is initiated via ARC the MT luminaire will automatically switch to mains mode after the functional or full duration test is completed.
AST (Advanced Self-Test)	This is a self-test luminaire. Functional test is carried out automatically once a week and runs for 30 seconds. Full duration test is carried out automatically every 52 weeks. First full duration test is carried out automatically within the first 4 weeks after the luminaire being connected to mains voltage. This luminaire can be used in conjunction with the Advanced Remote Control (ARC). ARC is an optional tool that adds extra features to AST emergency luminaires. Please refer to the ARC's user guide.
PST (Programmable Self-Test)	This is a programmable self-test luminaire. It must be used in conjunction with a Programmable Remote Control (PRC). Please refer to PRC's user guide.



# **GRANITE Emergency Bulkhead**

SPACING TABLE											
SPACING PADEL			An	ti-pan	ic 0.5	lux	Escape Route 1 lux				
Photometric curve	Model Number	Mounting height (m)	Lux level directly under	Transverse to Wall	Transverse to Transverse	Axial to Axial	Axial to Wall	Transverse to Wall	Transverse to Transverse	Axial to Axial	Axial to Wal
		2.5	27.9	4.6	11.1	11.2	4.6	3.8	9.4	9.3	3.8
	,	3	21.4	5.0	12.2	12.2	5.0	4.1	10.2	10.0	4.1
1967 100" 116" 146" 146" 136" 100" 100"		3.5	15.0	5.4	13.3	13.0	5.4	4.4	10.9	10.7	4.3
		4	8.6	5.7	14.0	13.8	5.6	4.5	11.5	11.3	4.5
		4.5	7.4	6.0	14.8	14.5	5.9	4.7	12.1	11.8	
		5	6.2	6.2	15.5	15.2	6.1	4.7	12.5	12.2	
		5.5	5.0	6.4	16.1	15.8	6.3	4.7	12.9	12.5	
	BHA3	6	3.8	6.5	16.7	16.3	6.4	4.6	13.2	12.8	
		6.5	3.4	6.6	17.2	16.8	6.5	4.5	13.4	13.0	
	7.5	7	3.0	6.7	17.7	17.2	6.5	4.3	13.5	13.0	
			2.5	6.7	18.0	17.6	6.5	4.0	13.5	13.1	
		- 8	2.1	6.6	18.4	17.8	6.5	3.7	13.4	13.0	
		8.5	2.0	6.5	18.6	18.1	6.4	3.3	13.2	12.8	Axial to Wa  3.8  4.1  4.3
30" 15' 15' 37'		9	1.8	6.4	18.8	18.3	6.3	2.7	13.0	12.6	
		9.5	1.6	6.3	19.0	18.4	6.2	1.9	12.7	12.3	
		10	1.4	6.0	19.1	18.4	5.9	0.0	12.2	11.9	0.0